

# CALL CMS FOR FINAL INSPECTION

## THE FOLLOWING ITEMS ARE CONDITIONS FOR PERMIT ISSUANCE FOR RE-SIDING.

### STRICT COMPLIANCE IS MANDATORY:

Exterior walls shall provide the building with a weather-resistive exterior wall envelope. The exterior wall envelope shall include flashing as described in section R703.8. The exterior wall envelope shall be designed and constructed in such a manner as to prevent the accumulation of water within the wall assembly by providing a water-resistive barrier behind the exterior veneer as required by section R703.2.

#### **1309.0703 SECTION R703, EXTERIOR COVERING.**

Subpart 1. **Section R703.2.** IRC section R703.2 is amended to read as follows:

**R703.2 Weather-resistive sheathing paper.** A minimum of one layer of No. 15 asphalt felt complying with ASTM D 226 for Type 1 felt or other approved weather-resistive material shall be applied over sheathing of all exterior walls.

**R703.4.** Such felt or material shall be applied horizontally, with the upper layer lapped over the lower layer not less than 2 inches (51 mm). Where joints occur, felt shall be lapped not less than 6 inches (152 mm). Building paper or other approved material shall be continuous to the top of the wall and terminated at penetrations and building appendages in such a manner to meet the requirements of the exterior wall envelope as described in Section R703.1.

**Exception:** Such felt or material is permitted to be omitted in the following situations:

1. In detached accessory buildings.
2. Where specifically prohibited by a sheathing and/or siding manufacturer.

### **SEE ATTACHED TABLE**

Subp. 2. **Table R703.4.** IRC Table R703.4 is amended to read as follows:

**TABLE R703.4**

#### **WEATHER-RESISTANT SIDING ATTACHMENT AND MINIMUM THICKNESS<sup>abcdefghijklmnopqrstuvwxyz</sup>**

	Nominal	Sheathing	
	<u>Thickness<sup>a</sup></u>	<u>Joint</u>	<u>Paper</u>
Siding material	(inches)	Treatment	Required
Horizontal aluminum <sup>e</sup>			
Without insulation	0.019 <sup>f</sup>	Lap	Yes
	0.024	Lap	Yes
With insulation	0.019	Lap	Yes
Brick veneer	2	Section	Yes

Concrete masonry veneer	2	R703	
Hardboard <sup>i</sup>			Yes
	7/16	Note q	Note q
Panel siding-vertical			
Sliding vertical			Yes
Hardboard <sup>i</sup>	7/16	Note q	Note q
Lap-siding-horizontal			
Steel <sup>i</sup>	29 ga.	Lap	Yes
Stone veneer	2	Section	Yes
		R703	
			Yes
	3/8 - 1/2	Note g	Note g
Particleboard panels			
			Yes
	5/8	Note g	Note g
Plywood panel <sup>j</sup>			Yes
(exterior grade)	3/8	Note g	Note g
Vinyl Siding <sup>n</sup>	0.035	Lap	Yes
Wood <sup>k</sup> Rustic, drop	3/8 Min	Lap	Yes
Shiplap	19/32 Average	Lap	Yes
Bevel	7/16	Lap	Yes
Butt tip	3/16	Lap	Yes

- a. Based on stud spacing of 16 inches on center where studs are spaced 24 inches, siding shall be applied to sheathing approved for that spacing.
- b. Nail is a general description and shall be T-head, modified round head, or round head with smooth or deformed shanks.
- c. Staples shall have a minimum crown width of 7/16-inch outside diameter and be manufactured of minimum No. 16 gage wire.
- d. Nails or staples shall be aluminum, galvanized, or rust-preventive coated and shall be driven into the studs for fiberboard or gypsum backing.
- e. Aluminum nails shall be used to attach aluminum siding.

- f. Aluminum (0.019 inch) shall be unbacked only when the maximum panel width is 10 inches and the maximum flat area is 8 inches. The tolerance for aluminum siding shall be +0.002 inch of the nominal dimension.
- g. All attachments shall be coated with a corrosion-resistive coating.
- h. Shall be of approved type.
- i. Three-eighths-inch plywood shall not be applied directly to studs spaced more than 16 inches on center when long dimension is parallel to studs. Plywood ½ inch or thinner shall not be applied directly to studs spaced more than 24 inches on center. The stud spacing shall not exceed the panel span rating provided by the manufacturer unless the panels are installed with the face grain perpendicular to the studs or over sheathing approved for that stud spacing.
- j. Woodboard sidings applied vertically shall be nailed to horizontal nailing strips or blocking set 24 inches in center. Nails shall penetrate 1.5 inches into studs and wood sheathing combined or blocking. A weather-resistant membrane shall be installed weatherboard fashion under the vertical siding unless the siding boards are lapped or battens are used.
- k. Hardboard siding shall comply with AHA A135.6.
- l. For masonry veneer, a weather-resistive sheathing paper is not required over a sheathing that performs as a weather-resistive barrier when a 1-inch air space is provided between the veneer and the sheathing. When the 1-inch space is filled with mortar, a weather-resistive sheathing paper is required over studs or sheathing.
- m. Vinyl siding shall comply with ASTM D 3679.
- n. Minimum shank diameter of 0.092 inch minimum head diameter of 0.225 inch, and nail length must accommodate sheathing and penetrate framing 1.5 inches.
- o. When used to resist shear forces, the spacing must be 4 inches at panel edges and 8 inches on interior supports.
- p. Minimum shank diameter of 0.099 inch, minimum head diameter of 0.240 inch, and nail length must accommodate sheathing and penetrate framing 1.5 inches.
- q. Vertical end joints shall occur at studs and shall be covered with a joint cover or shall be caulked.
- r. Fiber cement siding shall comply with the requirements of ASTM C 1186.
- s. See Section R703.10.1.
- t. Minimum 0.102" smooth shank, 0.255" round head.
- u. Minimum 0.099" smooth shank, 0.250" round head.
- v. See Section R703.10.2.
- w. Face nailing: 2 nails at each stud. Concealed nailing: one 11 gage 1-1/2 galv. roofing nail (0.371" head diameter, 0.120" shank) or 6d galv. box nail at each stud.
- x. See Section R703.2 exceptions.
- y. Minimum nail length must accommodate sheathing and penetrate framing 1-1/2 inches.
- z. Adhered masonry veneer shall comply with the requirements of Sections 6.1 and 6.3 of ACI 530/ASCE 5/TMS-402.

Subp. 9. **Section R703.8** IRC Section R703.8 is amended to read as follows:

**R703.8 Flashing.** Approved corrosion resistant flashing shall be applied shingle fashion in such a manner as to prevent entry of water into the wall cavity or penetration of water to the building structural framing components. The flashing shall extend to the surface of the exterior wall finish. Approved corrosion resistant flashing shall be installed at all of the following locations:

1. Exterior window and door openings. Flashing at exterior window and door openings shall extend to the surface of the exterior wall finish or to the water resistive barrier for subsequent drainage.
2. At the intersection of chimneys or other masonry construction with frame or stucco walls, with projecting lips on both sides under stucco copings.
3. Under and at the ends of masonry, wood, or metal copings and sills.
4. Continuously above all projecting wood trim.
5. Where exterior porches, decks, or stairs attach to a wall or floor assembly of wood frame construction.
6. At wall and roof intersections.
7. At built in gutters.
8. Where exterior material meets in other than a vertical line.
9. Where the lower portion of a sloped roof stops within the plane of an intersecting wall cladding in such a manner as to divert or kick out water away from the assembly.

**R703.10 Fiber cement siding.**

**R703.10.1 Panel siding.** Panels shall be installed with the long dimension parallel to framing. Vertical joints shall occur over framing members and shall be sealed with caulking or covered with battens. Horizontal joints shall be flashed with Z-flashing and blocked with solid wood framing.

**R703.10.2 Horizontal lap siding.** Lap siding shall be lapped a minimum of 1¼ inches (32mm) and shall have the ends sealed with caulking, covered with an H-section joint cover, or located over a strip of flashing. Lap siding courses may be installed with the fastener heads exposed or concealed, according to approved manufacturers' installation instructions.

**R703.11 Vinyl siding.** Vinyl siding shall be certified and labeled as conforming to the requirements of ASTM D 3679 by an approved quality control agency.

**R703.11.1 Installation.** Vinyl siding, soffit and accessories shall be installed in accordance with the manufacturer's installation instructions.



BUILDING PERMIT APPLICATION
City of St. Charles · 830 Whitewater Ave.
(P) 507-932-3020 (F) 507-932-5301

Date Received: Received by: Permit #:

APPLICANT - COMPLETE INFORMATION BELOW

Project Address: PID #:
Legal Description:
Property Owner: Phone:
Address: City: Zip:
General Contractor: License #: Phone:
Plumbing Contractor: License #: Phone:
Mechanical Contractor: Phone:

Proposed Use [Check All That Apply]:

Dwelling Commercial/Industrial Home Addition Garage Finish Basement
Windows Shed Deck Porch Fireplace Reroof Siding
Furnace A/C Water Heater Other

Description of Project:

Project Dimensions:
Use and Occupancy: Residential Commercial Industrial Other:
Type of Construction: Estimated Project Value: \$

This permit becomes null and void if work or construction authorized is not commenced within 180 days, or if construction or work is suspended or abandoned for a period of 180 days at any time after work has commenced. I hereby certify that I have read and examined this application and know the same to be true and correct. All provisions of laws and ordinances governing this type of work will be complied with whether specified herein or not. The granting of a permit does not presume to give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. REFUND POLICY: Upon request of cancellation of building permits, refunds will be based on expenses for office time, inspections, and zoning fees that were completed prior to the cancellation notice.

ZONING: Have there been any prior requests or zoning issues with this property? Yes No

Name [please print]: Address:
City/State: Zip: Phone:
Signature: Date:

CITY USE ONLY

PLANNING: Zoning District: Minimum Setbacks Required: Front Side
Rear Road Right-of-Way Other:

Subject to the following conditions:

Call PW Supt. for setback inspection (Kyle @ 507-259-7449) Call CMS for all applicable inspections

Approved by: Date:

BUILDING INSPECTOR USE ONLY

Approved by: Date:

FEES

Building Permit: Plan Review: St. Surcharge:
Plumbing Permit: Plan Review: St. Surcharge:
Mechanical Permit: Plan Review: St. Surcharge:
Sewer/Water Inspect. Sanitary Distr. Water mtr/copp:
Water Hookup: Sewer Hookup: Sump Pump Insp.
TOTAL DUE: Other:

Date Issued: Issued By: Receipt #:

**BUILDING PERMIT APPLICANT: PROPERTY OWNER**

I, \_\_\_\_\_, (print name) understand that the State of Minnesota requires that all residential building contractors, remodelers and roofers obtain a state license unless they qualify for a specific exemption from the licensing requirements. This license requirement applies to owners of residential real estate who build or improve such property for purposes of speculation or resale.

By signing this document, I attest to the fact that I am improving this house for my own use and am not building or improving this house for the purpose of reselling it. I hereby claim to be exempt from the state licensing requirements because I am not in the business of building or remodeling on speculation or for resale and that the house for which I am applying for this permit, located at \_\_\_\_\_ is the first residential structure I have built or improved in the past 24 months. I also acknowledge that because I do not have a state license, I forfeit any mechanic's lien rights to which I may otherwise have been entitled under Minn. Stat. §514.01.

Furthermore, I acknowledge that I may be hiring independent contractors to perform certain aspects of the construction or improvement of this house and I understand that some of these contractors may be required to be licensed by the State of Minnesota. I understand that unlicensed residential contracting, remodeling, and/or roofing activity is a misdemeanor under Minn. Stat. §326B.082, subd.16 and can also result in a fine of up to \$10,000. I further state that I understand that the filing of a false statement with the City/Township of \_\_\_\_\_ may also result in criminal prosecution and/or civil penalties pursuant to applicable city/township ordinances and/or state statutes.

I have also been informed and acknowledge that by listing myself as the contractor for this project, I alone will be responsible to the City/Township of \_\_\_\_\_ for compliance with all applicable building codes and city/township ordinances in connection with the work being performed on this property.

**Name (signature)** \_\_\_\_\_ **Date** \_\_\_\_\_

For questions or information on contractor licensing, or to check the licensing status and enforcement history of a particular contractor, call the Minnesota Department of Labor and Industry, Construction Codes and Licensing Division, at (651) 284-5069. The Web site is: [www.doli.state.mn.us/contractor](http://www.doli.state.mn.us/contractor)

(k:b&s/2008/misc/forms/selfwaiver\_rev1-08)

**BUILDING PERMIT APPLICANT: PROPERTY OWNER**

I, \_\_\_\_\_, (print name) understand that the State of Minnesota requires that all residential building contractors, remodelers and roofers obtain a state license unless they qualify for a specific exemption from the licensing requirements. This license requirement applies to owners of residential real estate who build or improve such property for purposes of speculation or resale.

By signing this document, I attest to the fact that I am improving this house for my own use and am not building or improving this house for the purpose of reselling it. I hereby claim to be exempt from the state licensing requirements because I am not in the business of building or remodeling on speculation or for resale and that the house for which I am applying for this permit, located at \_\_\_\_\_ is the first residential structure I have built or improved in the past 24 months. I also acknowledge that because I do not have a state license, I forfeit any mechanic's lien rights to which I may otherwise have been entitled under Minn. Stat. §514.01.

Furthermore, I acknowledge that I may be hiring independent contractors to perform certain aspects of the construction or improvement of this house and I understand that some of these contractors may be required to be licensed by the State of Minnesota. I understand that unlicensed residential contracting, remodeling, and/or roofing activity is a misdemeanor under Minn. Stat. §326B.082, subd.16 and can also result in a fine of up to \$10,000. I further state that I understand that the filing of a false statement with the City/Township of \_\_\_\_\_ may also result in criminal prosecution and/or civil penalties pursuant to applicable city/township ordinances and/or state statutes.

I have also been informed and acknowledge that by listing myself as the contractor for this project, I alone will be responsible to the City/Township of \_\_\_\_\_ for compliance with all applicable building codes and city/township ordinances in connection with the work being performed on this property.

**Name (signature)** \_\_\_\_\_ **Date** \_\_\_\_\_

For questions or information on contractor licensing, or to check the licensing status and enforcement history of a particular contractor, call the Minnesota Department of Labor and Industry, Construction Codes and Licensing Division, at (651) 284-5069. The Web site is: [www.doli.state.mn.us/contractor](http://www.doli.state.mn.us/contractor)